

## Monthly Average Water Quality for All Areas Except Kampala for the Month of December 2007

STATION	UNTREATED WATER					TREATED WATER						DISTRIBUTION				
	pH	Col (app) PtCo	Turb. NTU	F. Coli CFU/100ml		pH	Col (app) PtCo	Turb. NTU	F.Cl <sub>2</sub> mg/l			pH	Col (app) PtCo	Turb. NTU	F.Cl <sub>2</sub> mg/l	E. Coli CFU/100ml
<i>National Standard for Drinking water quality</i>						<b>6.5-8.5</b>	<b>≤15</b>	<b>≤5.0</b>	<b>≥0.20</b>			<b>6.5-8.5</b>	<b>≤15</b>	<b>≤5.0</b>	<b>≥0.20</b>	<b>0</b>
Entebbe	7.3-8.3	32	2.8	15		6.8-7.3	0	0.2	1.00			7.0-7.7	1	0.3	0.80	0
Jinja	7.07-8.27	78	7.0	11		6.71-7.43	10	2.0	1.11			7.00	10	2.0	0.30	0
Kasese	6.91-7.72	130	23.9	38		6.50-7.24	2	0.5	1.06			6.47-7.16	4	0.5	0.70	0
Masaka	4.54-6.37	207	36.8	62		7.26	5	0.8	1.06	Boma		7.33	10	1.0	0.65	0
						6.73-8.05	14	2.7	1.17	Bwala						
Kabale	7.3	30	3.0	20		7.4	1	0.0	0.73			7.20	2	0.2	0.60	0
Mbarara Ruharo	6.00-6.20	364	69.5	78		6.5-7.0	13	3.7	0.93	Ruharo		6.60	20	4.5	0.60	0
Mbarara Kabale Road	6.0-6.4	365	71.0	108		6.5-7.0	14	3.0	1.00	Oldline						
						6.30	15	4.0	1.20	Newline						
Arua	7.40-8.09	108	29.2	70		6.84	0	0.0	0.50			6.90	2	0.2	0.35	0
Bushenyi	5.89		23.5	44		6.35		6.9	0.50							
Soroti	7.12-7.91	95	4.9	34		7.07-7.79	1	0.7	1.25			7.33	5	1.0	0.52	0
Lira	8.23-8.80	58	11.0	6		7.49-7.85	12	1.3	0.47			7.16-7.71	12	1.3	0.20	0
Gulu	7.03-7.32	113	23.0	182		7.00-7.23	0	0	1.00			6.70-7.20	4	0.4	0.35	0

