

Report date: 09th March 2015

Table: Average water quality for Kampala during the period of 02nd - 08th March 2015

Parameter	Monitoring points							National Standard For potable water quality
	Unit	Treated Water Water Works	Water in Supply					
			Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.2	7.0	7.1	7.1	7.0	7.1	6.5- 8.5
Turbidity	NTU	0.30	0.38	0.36	0.40	0.24	0.37	≤ 5.00
Colour	PTU	2	2	2	3	2	3	≤ 15
Free chlorine	mg/l	0.50	0.35	0.30	0.35	0.35	0.25	0.2-0.5
E-Coli	CFU/100 ml	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	0	0	0	0	0	0	0