

Report date: 18th April 2011

Table: Average water quality for Kampala during the period of 11th - 17th April 11

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.1	7.3	7.1	7.2	7.0	7.1	7.2	6.5- 8.5
Turbidity	NTU	15.9	0.38	0.44	0.58	0.83	0.32	0.47	5.00
Colour	PTU	179	3	6	4	8	2	7	15
Free chlorine	mg/l	NA	1.10	0.35	0.30	0.35	0.35	0.30	0.2-0.5
E-Coli	CFU/100 ml	40	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	28	0	0	0	0	0	0	0

NA: Not applicable