

Report date: 18th April 2015

Table: Average water quality for Kampala during the period of 11th – 15th April 2015

Parameter	National Standard for portable water	Monitoring Points													
		Ntinda	City Centre	Mengo	Namugoona	Kalerwe	Kololo	Kitintale	Naguru	Kamwokya	Bukoto	Namanve	Seeta	Mutundwe	Wakiso
pH	6.5-8.5	7.1	7.0	7.0	7.1	7.2	7.0	7.2	7.1	7.1	7.3	7.1	7.2	7.0	7.0
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	1500	137	140	136	134	138	139	138	136	137	136	138	139	137	157
Turbidity (NTU)	5	0.45	0.37	0.73	0	0.39	0.26	0.52	0.67	0.95	0.98	0.34	0.72	0.58	0
Colour (PtCo)	15	8	3	11	0	8	3	2	8	10	10	9	6	10	0
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.40	0.30	0.30	0.30	0.20	0.25	0.35	0.40	0.40	0.25	0.25	0.28	0.20