

Report date: 19th January 2015

Table: Average water quality for Kampala during the period of 12th Jan 2015 - 18th Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.1	6.8	6.8	6.7	6.7	6.8	6.9	6.5- 8.5
Turbidity	NTU	15	0.43	0.43	0.40	0.39	0.13	0.40	≤ 5.00
Colour	PTU	181	3	6	4	3	2	5	≤ 15
Free chlorine	mg/l	NA	1.35	0.30	0.45	0.50	0.60	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	38	0	0	0	0	0	0	0

NA: Not applicable