

Report date: 20th June 2011

Table: Average water quality for Kampala during the period of 13th - 19th June 11

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.0	7.4	7.2	7.2	7.1	7.0	7.1	6.5- 8.5
Turbidity	NTU	15.0	0.55	0.62	0.58	0.73	0.56	0.82	≤ 5.00
Colour	PTU	112	3	4	2	5	1	5	≤ 15
Free chlorine	mg/l	NA	1.10	0.30	0.30	0.30	0.30	0.30	0.2-0.5
E-Coli	CFU/100 ml	50	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	30	0	0	0	0	0	0	0

NA: Not applicable