

Report date: 13th April 2015

Table: Average water quality for Kampala during the period of 13th - 17th April 2015

Parameter	National Standard for portable water	Monitoring Points													
		Luggala	City Centre	Nakulabye	Katwe	Mengo	Kalerwe	Makindye	Ndeeba	Luzira	Bweyogerere	Namuwongo	Kamwokya	Makerere	Lungujja
pH	6.5-8.5	7.1	7.0	7.3	7.0	6.8	7.0	7.3	7.2	7.0	7.1	7.0	6.9	6.8	7.1
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	1500	145	139	149	144	145	141	135	134	141	140	149	140	143	137
Turbidity (NTU)	5	0.21	0.16	0.13	0.58	0.83	0.00	0.61	0.68	0.88	0.78	0	0	0.82	0.94
Colour (PtCo)	15	6	2	5	9	11	9	8	11	10	8	2	0	7	9
Escherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.2	0.2	0.3	0.2	0.4	0.30	0.5	0.5	0.2	0.2	0.5	0.25	0.3	0.4