

**Report date:** 26<sup>th</sup> January 2015

**Table:** Average water quality for Kampala during the period of 19<sup>th</sup> Jan 2015 - 25<sup>th</sup> Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.0	7.1	7.0	7.1	7.0	7.0	7.1	6.5- 8.5
Turbidity	NTU	16	0.36	0.28	0.33	0.30	0.20	0.40	≤5.00
Colour	PTU	192	4	3	5	4	2	5	≤15
Free chlorine	mg/l	NA	1.26	0.25	0.35	0.45	0.45	0.20	0.20-0.50
E-Coli	CFU/100 ml	26	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	40	0	0	0	0	0	0	0

NA: Not applicable