

Report date: 27th June 2011

Table: Average water quality for Kampala during the period of 20th - 26th June 11

Parameter	Monitoring points								National Standard For potable water quality
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.8	7.2	7.1	7.1	7.1	7.0	6.9	6.5- 8.5
Turbidity	NTU	12.5	0.68	0.84	0.77	0.98	0.55	0.87	≤ 5.00
Colour	PTU	132	5	7	4	8	0	6	≤ 15
Free chlorine	mg/l	NA	1.20	0.35	0.30	0.30	0.30	0.25	0.2-0.5
E-Coli	CFU/100 ml	52	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	32	0	0	0	0	0	0	0

NA: Not applicable