

**Report date:** 27<sup>th</sup> April 2015

**Table:** Average water quality for Kampala during the period of 20<sup>th</sup> - 25<sup>th</sup> April 2015

Parameter	National Standard for portable water	Monitoring Points													
		Kisenyi	City centre	Nateete	Mulago	Old Kampala	Kyebando	Lubiri	Mutundwe	Wankulukuku	Bunamwaya	Namanve	Munyonyo	Kisaasi	Namugongo
pH	6.5-8.5	7.3	7.1	7.3	7.0	7.0	7.1	7.2	7.4	7.0	7.2	7.2	7.0	7.0	7.3
Electrical Conductivity ( $\mu\text{s}/\text{cm}$ )	1500	151	150	148	149	149	151	137	139.9	138	137	141	133	130	130
Turbidity (NTU)	5	0	0	0	0	0.8	0.16	0.13	0.69	0.99	0.14	0.28	0	0.17	0.69
Colour (PtCo)	15	0	1	1	2	4	3	3	5	9	2	6	1	3	5
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.3	0.4	0.3	0.35	0.3	0.30	0.3	0.3	0.35	0.3	0.2	0.4	0.3	0.2