

**Report date:** 02<sup>nd</sup> March 2015

**Table:** Average water quality for Kampala during the period of 23<sup>rd</sup> Feb - 01<sup>st</sup> March 2015

| Parameter           | Monitoring points |                                  |                    |                    |                      |                    |                     | National Standard<br><br>For potable water quality |
|---------------------|-------------------|----------------------------------|--------------------|--------------------|----------------------|--------------------|---------------------|--|
|                     | Unit              | Treated Water<br><br>Water Works | Water in Supply    |                    |                      |                    |                     |  |
|                     |                   |                                  | Rubaga<br>Division | Nakawa<br>Division | Makindye<br>Division | Kampala<br>Central | Kawempe<br>Division |  |
| pH                  | ...               | 7.2                              | 7.0                | 7.1                | 7.1                  | 7.0                | 7.1                 | 6.5- 8.5   |
| Turbidity           | NTU               | 0.35                             | 0.41               | 0.39               | 0.43                 | 0.21               | 0.47                | ≤ 5.00   |
| Colour              | PTU               | 2                                | 3                  | 2                  | 4                    | 2                  | 4                   | ≤ 15   |
| Free chlorine       | mg/l              | 0.50                             | 0.35               | 0.30               | 0.30                 | 0.25               | 0.28                | 0.2-0.5  |
| E-Coli              | CFU/100 ml        | 0                                | 0                  | 0                  | 0                    | 0                  | 0                   | 0  |
| Faecal -Streptococi | CFU/ 100 ml       | 0                                | 0                  | 0                  | 0                    | 0                  | 0                   | 0  |