

Report date: 2nd May 2011

Table: Average water quality for Kampala during the period of 25th April- 1st May 11

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.2	7.2	7.0	7.1	7.0	6.9	6.9	6.5- 8.5
Turbidity	NTU	14.1	0.38	0.45	0.41	0.68	0.24	0.51	5.00
Colour	PTU	172	2	4	3	6	0	4	15
Free chlorine	mg/l	NA	1.30	0.35	0.30	0.35	0.30	0.25	0.2-0.5
E-Coli	CFU/100 ml	50	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	38	0	0	0	0	0	0	0

NA: Not applicable