

Report date: 4th May 2015

Table: Average water quality for Kampala during the period of 27th - 30th April 2015

Parameter	National Standard for portable water	Monitoring Points													
		Najjanakumbi	Kololo	Rubaga	Namugooona	Kyengeru	Seguku	Buziga	Namasuba	Mukono	Bunamwaya	Luzira	Naguru	Kanyanya	Najjera
pH	6.5-8.5	7.0	7.1	6.9	7.1	7.0	6.9	7.0	7.3	7.0	7.1	7.0	7.2	7.2	7.2
Electrical Conductivity (µs/cm)	1500	138	148	137	138	141	137	137	138	137	138	135	133	140	139
Turbidity (NTU)	5	0.39	0	0.21	0.72	0.69	0.41	0	0.69	0.84	0.53	0.84	0	0.2	0.69
Colour (PtCo)	15	8	2	6	7	9	8	5	5	8	9	8	6	5	5
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.50	0.40	0.35	0.35	0.25	0.25	0.40	0.40	0.20	0.45	0.30	0.50	0.40	0.20