

Report date: 4th April 2011

Table: Average water quality for Kampala during the period of 28th March - 3rd April 11

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.3	7.4	7.1	7.1	7.3	7.2	7.2	6.5- 8.5
Turbidity	NTU	17.5	0.57	0.86	0.45	0.67	0.44	0.68	5.00
Colour	PTU	164	4	8	5	5	1	8	15
Free chlorine	mg/l	NA	1.25	0.30	0.35	0.25	0.35	0.25	0.2-0.5
E-Coli	CFU/100 ml	54	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	36	0	0	0	0	0	0	0

NA: Not applicable