

**Report date:** 9<sup>th</sup> May 2011

**Table:** Average water quality for Kampala during the period of 2<sup>nd</sup> - 8<sup>th</sup> May 11

Parameter	Monitoring points								National Standard  For potable water quality  (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.3	7.2	6.9	7.0	7.1	7.2	7.1	6.5- 8.5
Turbidity	NTU	18.5	0.64	0.58	0.61	0.84	0.31	0.66	5.00
Colour	PTU	168	3	4	4	6	0	5	15
Free chlorine	mg/l	NA	1.00	0.30	0.30	0.30	0.40	0.30	0.2-0.5
E-Coli	CFU/100 ml	56	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	36	0	0	0	0	0	0	0

NA: Not applicable