

Report date: 6th June 2011

Table: Average water quality for Kampala during the period of 30th May- 5th June 11

Parameter	Monitoring points								National Standard For potable water quality
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.8	7.4	7.2	7.2	7.1	7.0	7.2	6.5- 8.5
Turbidity	NTU	10.5	0.77	0.87	0.75	1.00	0.49	0.97	≤ 5.00
Colour	PTU	128	7	7	4	8	1	8	≤ 15
Free chlorine	mg/l	NA	1.20	0.30	0.35	0.30	0.35	0.30	0.2-0.5
E-Coli	CFU/100 ml	46	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	28	0	0	0	0	0	0	0

NA: Not applicable