

Report date: 12th January 2015

Table: Average water quality for Kampala during the period of 5th - 11st Jan 2015

Parameter	Monitoring points								National Standard For potable water quality
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.3	7.1	7.2	7.2	7.1	7.2	7.2	6.5- 8.5
Turbidity	NTU	17	0.26	0.41	0.32	0.30	0.29	0.33	≤ 5.00
Colour	PTU	195	3	2	6	5	1	4	≤ 15
Free chlorine	mg/l	NA	1.36	0.30	0.50	0.40	0.50	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	44	0	0	0	0	0	0	0

NA: Not applicable