

Report date: 13th June 2011

Table: Average water quality for Kampala during the period of 6th - 12th June 11

Parameter	Monitoring points								National Standard For potable water quality
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.9	7.5	7.2	7.2	7.2	7.1	7.2	6.5- 8.5
Turbidity	NTU	11.9	0.82	1.10	0.68	1.20	0.58	1.20	≤ 5.00
Colour	PTU	149	8	9	6	8	1	8	≤ 15
Free chlorine	mg/l	NA	1.20	0.35	0.35	0.35	0.30	0.30	0.2-0.5
E-Coli	CFU/100 ml	48	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	26	0	0	0	0	0	0	0

NA: Not applicable