

Report date: 16th May 2011

Table: Average water quality for Kampala during the period of 9th - 15th May 11

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.6	7.4	7.3	7.1	7.1	7.2	7.2	6.5- 8.5
Turbidity	NTU	20.2	0.94	0.78	0.72	1.45	0.37	1.20	5.00
Colour	PTU	156	8	7	7	8	0	6	15
Free chlorine	mg/l	NA	1.00	0.40	0.30	0.35	0.30	0.40	0.2-0.5
E-Coli	CFU/100 ml	52	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	38	0	0	0	0	0	0	0

NA: Not applicable