

## WOBULENZI AREA

**Report date:** 13<sup>th</sup> July 2015

**Table:** Water quality for selected points in Wobulenzi during the week of 6<sup>th</sup> July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Networth	Wobulenzi Central	Kisawe	
pH	...	6.35	6.37	6.47	6.67	6.56	5.5 – 8.5
Turbidity	NTU	0.732	0.254	0.204	0.310	0.327	≤5
Colour	PtCo.	0	0	0	0	0	≤15
Free chlorine	mg/L	NA	0.2	0.2	0.2	0.2	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	290	0	0	0	0	0