

WOBULENZI AREA**Report date:** 29th June 2015**Table:** Water quality for selected points in Wobulenzi during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				NWSC	Networth	Wobulenzi central	psp Kisawe	
pH	...	6.73	6.60	6.31	6.42	6.34	6.32	5.5 – 8.5
Turbidity	NTU	1.55	0.35	0.45	0.59	5.00	2.34	≤5
Colour	PtCo.	2	3	2	0	1	5	≤15
Free chlorine	mg/L	N/A	0.4	0.4	0.35	0.35	0.3	0.20 – 0.50
Faecal -Coliform	CFU/100 mL	104	0	0	0	0	0	0