

ZIROBWE AREA**Report date:** 6th January -2016**Table:** Water quality for Selected points in Entebbe during the week starting 31st December 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Nambi	Zirobwe central	Namawoja	Busulwa	
CODE		N010	N011	N012	N013	N014	N015	
pH	7.2	7.4	7.3	7.4	7.6	7.5	5.5 – 8.5
Turbidity	NTU	0.23	0.26	0.27	0.21	0.27	0.23	≤5.00
Colour	PtCo.	5	0	4	3	3	3	≤15
Iron	Mg/l	0.044	0.019	0.00	0.00	0.00	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.53	0.30	0.20	0.20	0.30	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	2	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required