

**ZIROBWE AREA****Report date:** 22<sup>nd</sup> June 2015**Table:** Water quality for selected points in Ziobwe during the week of 15<sup>th</sup> June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Nambi SS	Nambi Health Centre	Wakatayi	Busulwa Residence	Namawoja	
pH	...	6.30	6.71	6.76	6.74	6.88	7.06	6.64	5.5 – 8.5
Turbidity	NTU	1.27	0.52	0.36	0.61	0.47	1.32	0.37	≤5
Colour	PtCo.	5	0	0	0	0	0	0	≤15
Free chlorine	mg/L	N/A	0.4	0.2	0.3	0.2	0.1	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	15	0	0	0	0	0	0	0