

Report date: 25th May 2015

Table: Average water quality for Kampala during the period of 18th - 22nd May 2015

Parameter	National Standard for portable water	Monitoring Points													
		Lugogo	Buloba	Busoga	Nabingo	Wandegeya	Bwaise	Kawanda	Matugga	Luzira	Namuwongo	Kabalagala	Nsambya	Busabala	Zana
pH	6.5-8.5	7.0	7.29	7.11	7.23	7.23	7.2	7.1	7.21	7.0	7.1	7.1	7.2	7.04	7.01
Electrical Conductivity (µs/cm)	1500	131	138	136	137	133	134	133	132	137	134	134	133	133	133
Turbidity (NTU)	5	0.62	0.70	0.35	0	0	0.28	0	0	0	0.08	0.51	0.48	0.32	0.57
Colour (PtCo)	15	8	5	4	0	0	0	0	0	0	10	5	7	9	11
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.30	0.30	0.25	0.20	0.45	0.30	0.25	0.25	0.30	0.30	0.50	0.40	0.25	0.20