

Report date: 1st June 2015

Table: Average water quality for Kampala during the period of 25th - 29th May 2015

Parameter	National Standard for portable water	Monitoring Points													
		City centre	Mutungo	Rubaga	Kyanja	Kanyanya	Ntinda	Nakawa	Kireka	Mukono	Kibuli	Buziga	Munyonyo	Namasuba	Lubowa
pH	6.5-8.5	7.0	7.09	7.16	7.24	7.0	7.1	7.3	7.23	7.06	7.06	7.11	7.1	7.06	7.14
Electrical Conductivity (µs/cm)	1500	138	133	134	135	135	138	133	137	134	135	130	134	136	138
Turbidity (NTU)	5	0.65	0.04	0.29	0.58	0.44	0.38	0.67	0.16	0.41	0.64	0.55	0.77	0.89	0.57
Colour (PtCo)	15	5	10	7	9	11	6	8	8	10	3	0	0	2	1
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.35	0.25	0.20	0.45	0.30	0.30	0.40	0.30	0.25	0.20	0.25	0.25	0.40	0.25