

Report date: 15th June 2015

Table: Average water quality for Kampala during the period of 8th - 12th June 2015

Parameter	National Standard for portable water	Monitoring Points													
		City centre	Kawempe	Nakasero	Matugga	Namungoona	Kyambogo	Kireka	Kirinya	Mukono	Luzira	Seeta	Muyenga	Makerere	Bukoto
pH	6.5-8.5	7.0	7.3	7.2	7.1	7.0	7.0	7.3	7.2	7.0	7.2	7.0	7.2	7.3	7.1
Electrical Conductivity ($\mu\text{S/cm}$)	1500	139	145	144	147	138	136	141	145	143	147	137	145	146	143
Turbidity (NTU)	5	0.08	0.31	0.24	0.39	0.24	0.21	0.21	0.20	0.22	0.18	0.21	0	0.29	0.21
Colour (PtCo)	15	0	9	4	10	8	6	7	5	6	3	5	0	7	6
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.40	0.45	0.35	0.25	0.25	0.30	0.30	0.40	0.30	0.35	0.30	0.45	0.40	0.25