

Report date: 13th November 2023

Table: Average water quality for Kampala Water during the period running 06th - 12th November 2023

Parameter	National Standard For Potable Water	Monitoring Points															
		Kansanga Mt. Carmel	Ggaba Market	Bunga market	Luwafu Washing Bay	Joggo Trading Center	Mukono Health Center IV	Seeta 12 Miles Village (Namilyango Road)	Seeta market	Nansana Market	Nansana Nabweru Road	Bwaise Industrial Area	Bwaise Washing Bay	Kawempe Mbogo Islamic P/S	Makerere Primary School	Mawanda Road - Denaro Apartment	Namuwongo Market
Electrical Conductivity (µs/cm)	≤1500	109	134	134	133	107	108	106	100	131	131	146	142	146	142	147	128
pH	6.5-8.5	7.2	7.2	7.2	7.1	7.5	7.8	7.7	7.6	7.1	7.1	6.8	6.9	6.7	6.9	6.8	6.9
Turbidity (NTU)	≤5	0.69	0.41	0.98	1.17	0.37	0.41	0.41	0.52	0.80	0.77	0.99	0.90	0.99	0.97	0.88	0.79
Colour – Apparent (PtCo)	≤15	1	0	11	12	4	4	3	4	4	0	12	11	8	11	9	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.25	0.40	0.40	0.30	0.40	0.30	0.20	0.20	0.20	0.20	0.20	0.50	0.40
Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for potable water.



Denis Smith Akejo
Senior Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: