

Report date: 20<sup>th</sup> November 2023

Table: Average water quality for Kampala Water during the period running 13<sup>th</sup> - 19<sup>th</sup> November 2023

Parameter	National Standard For Potable Water	Monitoring Points														
		Ggaba Road PV	Buziga Islamic Institute	Kansanga Hill Primary School	Salaama Road/ Zikusooka Road Junction	Ndeeba Kasumba Zone	Lubowa Police Post	Nalukolongo Market	Kyengera Trading Center	Nyanama Trading Center	Mutundwe PAPSCA	Nabingo Trading Center	Masaka Road SV	Munyonyo Mawanga Zone	Bunga market	Kabojja Parents Primary School
Electrical Conductivity (µs/cm)	≤1500	135	127	130	133	125	125	129	127	137	129	132	135	127	133	130
pH	6.5-8.5	7.0	6.9	6.9	7.1	7.0	7.3	7.1	7.1	6.8	7.1	7.0	7.1	7.0	6.9	7.0
Turbidity (NTU)	≤5	0.42	0.96	1.01	0.81	0.81	0.95	0.83	0.78	0.87	0.88	0.64	0.98	0.94	0.44	0.72
Colour – Apparent (PtCo)	≤15	0	6	9	6	7	7	5	5	6	5	4	8	8	1	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.50	0.20	0.30	0.30	0.40	0.35	0.30	0.30	0.30	0.20	0.20	0.30	0.35
Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: