

Report date: 02<sup>nd</sup> October 2023

Table: Average water quality for Kampala Water during the period running 25<sup>th</sup> September - 01<sup>st</sup> October 2023

Parameter	National Standard For Potable Water	Monitoring Points															
		Kasengejje Road	Lyna Nursery School	Namuwongo Godown	Bugolobi market	Mutungo Trading Center	Bweyogerere Kazinga zone	Namugongo Jjanda	Ntinda Ministers' Village	Lugogo Bypass	Bulaga Police Post	Bulenga Trading Center	Decent Living Project Bujuuko	Kireka Bbira	Lugala Trading Centre	Seeta Market	Kawanda Trading Center
Sample ID		11983	12021	12024	12032	12036	12041	12057	12059	12065	12068	12073	12077	12079	12087	12116	12214
Electrical Conductivity (µs/cm)	≤1500	151	154	156	139	103	107	107	122	144	139	141	151	140	155	108	148
pH	6.5-8.5	7.0	7.1	7.1	7.1	7.7	7.9	7.8	7.9	7.3	7.1	7.1	7.3	7.2	7.2	7.7	7.1
Turbidity (NTU)	≤5	0.29	0.76	0.61	0.38	0.34	0.57	1.46	0.48	0.38	0.49	0.44	0.57	0.62	0.60	0.73	0.69
Colour – Apparent (PtCo)	≤15	5	5	6	3	3	6	13	5	3	8	4	6	7	6	8	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.45	0.25	0.30	0.40	0.40	0.25	0.30	0.30	0.30	0.30	0.30	0.40	0.40	0.40

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: