
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 08<sup>th</sup> January 2024

**Table: Average water quality for Kampala Water during the period running 01<sup>st</sup> - 07<sup>th</sup> January 2024**

Parameter	National Standard For Potable Water	Monitoring Points														
		Ggaba Seminary	Salaama Road	Arkrigh Road Seeta - Near Hill Top P/S	Namboole Trading Center	Kitukutwe Trading Center	Najjera I	Lake Victoria Serena - Mutungo	Mestil Hotel	Protea Hotel	Golden Tulip Hotel	Sir Jose Hotel	Sheraton Hotel	Course Hotel	Busabala Road, Masajja TC	Busabala - Kirinda C
Electrical Conductivity (µs/cm)	≤1500	148	164	111	110	111	114	152	156	156	157	154	166	161	141	149
pH	6.5-8.5	7.3	6.9	6.9	6.8	7.3	7.1	6.9	6.8	6.7	6.9	6.9	7.1	7.0	6.8	6.8
Turbidity (NTU)	≤5	0.69	0.91	0.87	0.64	0.40	0.54	0.26	0.76	0.75	0.48	0.99	0.67	0.98	0.94	0.57
Colour – Apparent (PtCo)	≤15	2	10	0	0	0	0	0	3	3	0	9	0	6	10	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.30	0.30	0.30	0.30	0.40	0.40	0.25	0.30	0.45	0.30	0.40	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: