
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 17<sup>th</sup> January 2024

**Table: Average water quality for Kampala Water during the period running 08<sup>th</sup> - 14<sup>th</sup> January 2024**

Parameter	National Standard For Potable Water	Monitoring Points														
		Ggaba Market	Nsambya Kirombe	Usafi market	Uganda Management Institute	Kyebando Ring Road SV	Ntinda New Market	St. Luke C.O.U Ntinda	Kiswa Health Center	AM Luzira Water Village Quarters	Mawanda Road - Denaro Apartment	Mutundwe Kisigula	Kawempe Mbogo Islamic	Kisenyi Bus Terminal	Kisenyi III Kiti Zone	St. Francis High School - Namagoma
Electrical Conductivity (µs/cm)	≤1500	165	170	155	154	148	158	118	168	160	147	161	149	149	151	168
pH	6.5-8.5	7.1	7.0	7.2	7.2	7.2	6.7	7.0	7.4	6.6	7.2	6.8	7.2	7.2	7.2	6.8
Turbidity (NTU)	≤5	0.86	1.15	0.62	0.59	0.55	0.82	0.71	0.64	0.72	0.70	1.12	0.68	0.59	0.58	0.91
Colour – Apparent (PtCo)	≤15	7	8	8	5	6	7	6	0	4	8	10	5	5	5	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.40	0.40	0.30	0.35	0.40	0.30	0.40	0.40	0.30	0.30	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: