
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 19<sup>th</sup> February 2024

**Table: Average water quality for Kampala Water during the period running 12<sup>th</sup> - 18<sup>th</sup> February 2024**

Parameter	National Standard For Potable Water	Monitoring Points														
		Ggaba Market	Kansanga Mt. Carmel	Nsambya Xavier	Ndejje Kanyanya Zone	Kigo Mutungo market	Portbell Market	Kireka Market	Bugolobi Sewerage Works	All Saints Cathedral Nakasero	Fairway Hotel	Buddo Trading Center	Kalinabiri Ntinda	Butabika Hospital	Naalya Estate	Mukono Dandira
Electrical Conductivity (µs/cm)	≤1500	164	146	156	145	151	148	147	147	139	140	153	126	111	125	110
pH	6.5-8.5	8.0	7.7	7.0	8.1	8.1	7.6	7.7	7.7	6.7	6.8	6.5	6.7	6.6	6.7	6.8
Turbidity (NTU)	≤5	0.26	0.66	1.10	0.60	0.57	0.91	0.79	0.59	0.38	0.42	0.66	0.81	0.40	0.32	0.49
Colour – Apparent (PtCo)	≤15	0	6	13	6	6	11	9	8	8	7	7	8	2	9	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.40	0.40	0.50	0.40	0.40	0.45	0.40	0.30	0.40	0.30	0.25	0.30	0.45
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: