
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th February 2024

Table: Average water quality for Kampala Water during the period running 19th - 25th February 2024

Parameter	National Standard For Potable Water	Monitoring Points														
		Ndeeba Kasumba Zone	Lubowa Police Post	Bulindo Kiwologoma TC	Namugongo Jjanda	Seeta Bajjo Trading Center	Valve Near Coca Cola	Bweyogerere Butto	Kyaliwajjala Trading Center	Buloba Bukasa TC	City Abattoir	Green Hill Academy Kibuli	Kawempe Police Station	Kisugu Police Station	Arua Park	Kitemu Nsangi
Electrical Conductivity (µs/cm)	≤1500	120	114	110	110	110	111	110	110	161	150	150	170	170	150	163
pH	6.5-8.5	6.8	6.5	6.7	6.6	6.8	7.0	6.4	6.5	6.5	6.6	6.6	6.5	6.5	6.4	6.7
Turbidity (NTU)	≤5	0.78	0.55	0.51	0.50	0.50	0.38	0.57	0.43	1.01	0.32	0.45	0.43	0.51	0.44	0.89
Colour – Apparent (PtCo)	≤15	6	4	6	6	5	1	5	4	10	6	5	8	4	4	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.25	0.30	0.40	0.50	0.45	0.30	0.30	0.30	0.40	0.40	0.40	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Senior Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: