
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 17th February 2025

Table: Average water quality for Kampala Water during the period running 10th February - 16th February 2025

Parameter	National Standard For Potable Water	Monitoring Points								
		Nakasero Gun Hill Tank A2	Mengo Hospital Main Gate	Bulange Kivebulaya Rd Jn V-1564	Cooper Complex	Kisenyi I Musajjalumbwa Road	Kitante Hill School	Katanga Near JB Girls' Hostel	Kisenyi Bus Terminal	Namirembe Booster
Electrical Conductivity (µs/cm)	≤1500	141	146	147	146	142	144	175	146	146
pH	6.5-8.5	7.5	7.7	7.7	7.7	7.4	7.7	7.7	7.8	7.8
Turbidity (NTU)	≤5	0.75	0.82	0.88	0.68	0.45	0.58	0.45	0.75	0.61
Colour – Apparent (PtCo)	≤15	8	8	6	4	5	4	4	7	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.40	0.20	0.20	0.20	0.20	0.20	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: