
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 24th February 2025

Table: Average water quality for Kampala Water during the period running 17th February - 23rd February 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Ntenjeru Trading Center	Wakiso District Headquarters	Nyanama Trading Center	Bwaise Kazo zone	City Abattoir	Katanga Soweto Zone	Kawempe Police Station	Ntinda New Market	Mbuya Comboni Sisters	Seeta Bajjo Trading Center
Electrical Conductivity (µs/cm)	≤1500	95	186	148	139	138	137	138	129	169	111
pH	6.5-8.5	7.5	7.3	7.8	7.2	7.1	7.1	7.1	7.7	7.9	7.2
Turbidity (NTU)	≤5	0.34	0.50	0.62	0.34	0.35	0.30	0.50	0.79	0.55	0.28
Colour – Apparent (PtCo)	≤15	1	0	8	3	4	3	3	6	4	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.20	0.20	0.30	0.30	0.40	0.40	0.30	0.35	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 24th February 2025

Table: Average water quality for Kampala Water during the period running 17th February - 23rd February 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namugongo Jjanda	Bulindo Kiwologoma TC	Bweyogerere Butto	Kagoma Islamic P/S	Mawanda Road - Denaro Apartment	Lubiri High School	Mengo Kisenyi, Nanyonzi Zone	Luzira Market	Kinawataka Police Post	Naalya L.C. 1
Electrical Conductivity (µs/cm)	≤1500	111	107	133	139	138	137	138	137	127	127
pH	6.5-8.5	7.3	7.3	7.7	7.2	7.3	7.3	7.2	7.5	7.5	7.0
Turbidity (NTU)	≤5	0.44	0.35	0.69	0.28	0.46	0.31	0.50	0.66	0.51	0.55
Colour – Apparent (PtCo)	≤15	6	4	6	3	3	4	4	4	4	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.20	0.20	0.40	0.30	0.20	0.30	0.35	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: