
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th January 2025

Table: Average water quality for Kampala Water during the period running 20th January - 26th January 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Ndeeba Nsiike Zone	Katale Lunya	Kiswa Primary School	Kasangati Bulamu zone	Kireka SDA Primary School	Bweyogerere Butto	Bunga market	Ggaba Road PV	Valve Near Coca Cola	Mukono Lwanyonyi TC
Electrical Conductivity (µs/cm)	≤1500	143	143	154	115	153	153	158	155	108	107
pH	6.5-8.5	7.3	7.2	7.0	8.1	6.8	6.7	7.1	6.8	7.6	8.0
Turbidity (NTU)	≤5	0.53	0.56	0.57	0.55	0.63	0.82	0.31	0.84	0.37	0.32
Colour – Apparent (PtCo)	≤15	5	5	6	5	6	8	0	7	3	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.40	0.35	0.40	0.40	0.30	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th January 2025

Table: Average water quality for Kampala Water during the period running 20th January - 26th January 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Buloba PTC	Nakasero Booster	Kasubi Market	Namungoona Booster	Ntinda Old Market	Kyaliwajjala Trading Center	Green Hill Academy Buwate	Bulindo Kiwologoma TC	Nabingo Trading Center	Kyengera Central College
Electrical Conductivity (µs/cm)	≤1500	148	147	146	146	126	105	108	108	149	153
pH	6.5-8.5	7.5	7.3	7.2	7.4	7.1	7.3	7.3	7.3	7.3	7.0
Turbidity (NTU)	≤5	0.32	0.34	0.67	0.62	0.56	0.41	0.42	0.46	0.66	0.48
Colour – Apparent (PtCo)	≤15	2	0	0	0	7	5	4	6	4	1
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.45	0.20	0.35	0.30	0.30	0.25	0.30	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: