
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 10th March 2025

Table: Average water quality for Kampala Water during the period running 03rd March - 09th March 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Luzira Butabika	Namboole Trading Center	Luteete Trading Center	Bwaise Happy Hours	Centenary Park Booster	Mengo Bulange	Nakulabye Market	Yowanamaria (WSP 47 11C)	Ntinda UNEB	Buwate Sub-Branch - NWSC Office
Electrical Conductivity (µs/cm)	≤1500	146	111	101	157	158	156	156	140	143	125
pH	6.5-8.5	7.3	7.3	7.3	7.6	7.6	7.6	7.6	7.8	7.5	7.8
Turbidity (NTU)	≤5	0.92	0.53	0.35	0.95	0.49	0.65	0.64	1.22	1.02	0.42
Colour – Apparent (PtCo)	≤15	9	10	3	10	6	9	0	10	8	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.25	0.30	0.40	0.20	0.30	0.40	0.40	0.20	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 10th March 2025

Table: Average water quality for Kampala Water during the period running 03rd March - 09th March 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Mukono Wantoni	Mukono Health Center IV	Joggo Trading Center	Mutesa I Royal University	Lungujja Kosovo	Kiira Kasangati Road	Bulindo Kiwologoma TC	Kanyanya Kimali Zone	Manyangwa TC - Gayaza
Electrical Conductivity (µs/cm)	≤1500	111	112	111	111	166	169	118	110	141	97
pH	6.5-8.5	7.7	7.6	7.7	8.3	8.0	7.8	7.8	7.3	7.2	7.2
Turbidity (NTU)	≤5	0.83	0.70	0.87	0.62	0.70	0.77	0.34	0.56	0.91	0.39
Colour – Apparent (PtCo)	≤15	7	3	9	7	5	8	8	3	9	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.40	0.40	0.30	0.30	0.25	0.20	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: