
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 14th April 2025

Table: Average water quality for Kampala Water during the period running 07th April - 14th April 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Namilyango Trading Center	Goma Misindye Zone	Sonde Village	Naalya Estate	Kalinabiri Ntinda	Kisenyi Bus Terminal	Kisenyi III Kiti Zone	Old Kampala S. S.	Wandegeya Police Station
Electrical Conductivity (µs/cm)	≤1500	103	104	106	146	105	146	130	133	135	135
pH	6.5-8.5	7.1	7.4	7.5	7.5	7.5	7.5	7.2	7.1	7.1	7.1
Turbidity (NTU)	≤5	0.61	0.63	0.10	0.20	0.33	0.28	0.83	0.86	0.87	0.93
Colour – Apparent (PtCo)	≤15	5	4	0	0	0	0	6	7	7	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.35	0.30	0.20	0.30	0.25	0.20	0.20	0.20	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 14th April 2025

Table: Average water quality for Kampala Water during the period running 07th April - 14th April 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Wankululuk u Kabowa	Zana Market	Kitante Hill School	Kanyanya Police Post	Portbell Market	Wakiso District Headquarters	Wakiso Kayunga Ward	Mukono Dandira	Nansana Nabweru Road	Mutundwa Kisigula
Electrical Conductivity (µs/cm)	≤1500	132	146	150	147	184	150	146	98	148	147
pH	6.5-8.5	7.1	7.3	7.1	7.6	7.0	7.0	6.8	7.7	6.9	7.5
Turbidity (NTU)	≤5	0.61	0.51	0.82	0.92	1.02	0.47	0.46	0.82	0.61	0.72
Colour – Apparent (PtCo)	≤15	5	6	6	10	11	2	6	3	8	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.40	0.30	0.30	0.30	0.25	0.35	0.35	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: