
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 17th March 2025

Table: Average water quality for Kampala Water during the period running 10th March - 16th March 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nansana Nabweru Road	5th Street - Kibira Road	Kinawataka Road SV	Portbell Market	Katanga Nea JB Girls' Hostel	Kanyanya Police Post	Kyebando Nsooba	Ndejje Kanyanya Zone	Kigo Mutungo market	Ntenjeru Trading Center
Electrical Conductivity (µs/cm)	≤1500	138	107	136	136	148	141	142	135	135	95
pH	6.5-8.5	7.1	7.5	6.9	6.9	7.1	7.2	7.2	7.0	6.9	7.3
Turbidity (NTU)	≤5	1.03	0.52	1.38	1.32	0.88	1.40	1.36	0.58	0.81	0.58
Colour – Apparent (PtCo)	≤15	10	4	10	11	9	12	13	5	8	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.50	0.40	0.30	0.20	0.40	0.30	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 17th March 2025

Table: Average water quality for Kampala Water during the period running 10th March - 16th March 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Busabala Road Clinic	Bandwe Tank	St. Francis High School Namagoma	Naalya Estate	Ntinda Old Market	Mukono Dandira	Namilyango Trading Center	Sonde Village	Namungoona Lower Estate	Cooper Complex
Electrical Conductivity (µs/cm)	≤1500	139	140	143	121	122	107	104	107	145	146
pH	6.5-8.5	7.0	7.1	7.4	7.6	7.5	7.4	7.5	7.5	7.0	7.1
Turbidity (NTU)	≤5	0.87	0.53	0.66	0.62	0.74	0.41	0.42	0.81	0.99	1.55
Colour – Apparent (PtCo)	≤15	8	4	3	3	3	0	1	2	11	11
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.40	0.30	0.30	0.30	0.30	0.40	0.35	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: