
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 07th April 2025

Table: Average water quality for Kampala Water during the period running 31st March - 06th April 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nonve Sump	Kakiri Police Division	Ggaba Seminary	Makindye Kizungu Zone	Mulago Market	Mengo Bulange	Kisenyi III Kiguli Zone	Jomayi Estates Nabusugwe	Kitukutwe Trading Center	Najjera II
Electrical Conductivity (µs/cm)	≤1500	176	218	148	146	152	156	151	108	109	100
pH	6.5-8.5	6.9	6.6	7.0	6.9	6.8	7.1	7.0	7.6	7.7	7.7
Turbidity (NTU)	≤5	0.20	0.13	0.64	0.58	0.96	0.97	1.29	0.70	0.83	0.93
Colour – Apparent (PtCo)	≤15	0	0	6	4	10	10	13	6	9	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.25	0.25	0.20	0.20	0.25	0.40	0.20	0.30	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 07th April 2025

Table: Average water quality for Kampala Water during the period running 31st March - 06th April 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Buwate Community	Luzira Market	Namboole Trading Center	Kirinya Bukasa	Kabowa Village	Namasuba St. Elizabeth	Joggo Trading Center	Mukono Market	Arkright Road Seeta - Near Hill Top P/S	Sonde Trading Center
Electrical Conductivity (µs/cm)	≤1500	110	151	106	101	149	151	103	103	105	103
pH	6.5-8.5	7.5	6.8	7.2	7.4	7.3	7.1	7.5	7.5	7.5	7.5
Turbidity (NTU)	≤5	0.44	0.83	0.46	0.51	0.33	1.19	0.39	0.47	0.42	0.66
Colour – Apparent (PtCo)	≤15	0	7	2	3	0	13	0	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.30	0.30	0.20	0.20	0.30	0.40	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: