
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 05th May 2025

Table: Average water quality for Kampala Water during the period running 28th April - 04th May 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kiswa Primary School	Kinawataka Police Post	Luzira Prisons	Nakawa Market	Nansana Market	Wakiso District Headquarters	Buwanuka Tank	Matuga Kinyonyira Zone	Kawanda Trading Centre	St. Luke C.O.U Ntinda
Electrical Conductivity (µs/cm)	≤1500	149	152	160	158	133	136	195	139	138	131
pH	6.5-8.5	6.9	7.0	7.0	6.9	7.0	6.9	7.2	6.8	7.1	7.2
Turbidity (NTU)	≤5	0.67	0.76	0.65	0.45	0.68	0.53	0.21	0.47	0.50	0.77
Colour – Apparent (PtCo)	≤15	9	8	8	6	8	4	1	1	1	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.30	0.45	0.20	0.20	0.40	0.20	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 05th May 2025

Table: Average water quality for Kampala Water during the period running 28th April - 04th May 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kulambiro Pal & Lisa School	Kyambogo Booster	Kireka Market	Kisoga Trading Centre	Katosi Trading Centre	Komamboga Kwata Zone	Nakanako Forest Estate	Kasangati market	Kungu Trading Centre	Twinbrook Kindergarter Bamba
Electrical Conductivity (µs/cm)	≤1500	129	157	154	93	94	104	106	106	108	109
pH	6.5-8.5	7.2	6.9	6.9	7.3	7.4	7.1	7.1	6.9	7.2	7.1
Turbidity (NTU)	≤5	0.78	0.47	0.61	0.38	0.52	0.32	0.52	0.40	0.48	0.50
Colour – Apparent (PtCo)	≤15	9	6	8	2	4	4	4	4	5	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.45	0.30	0.20	0.25	0.30	0.20	0.30	0.20	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: