
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 14<sup>th</sup> July 2025

**Table:** Average water quality for Kampala Water during the period running 07<sup>th</sup> June - 13<sup>th</sup> July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Busabala Road, Masajja TC	Nalumunye Jomayi Estates	Bunamwaya Kitebi	Kibuli Trading Center	St. Banarbas P/S - Kisugu	Buddo Trading Center	Nateete Market	Mutundwe Kisigula	Kabowa Village	Bukasa TC Muyenga
Electrical Conductivity (µs/cm)	≤1500	137	140	141	140	140	139	146	140	317	144
pH	6.5-8.5	7.3	7.2	7.2	7.3	7.4	7.6	7.1	7.5	7.7	7.6
Turbidity (NTU)	≤5	0.97	0.31	0.55	0.95	1.03	0.53	0.50	0.57	0.23	0.92
Colour – Apparent (PtCo)	≤15	9	0	0	10	11	5	0	3	0	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.20	0.40	0.45	0.20	0.20	0.20	0.20	0.45
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

### Remarks



The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo

**Principal Quality Control Officer – KW**

*Written by:*

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 14<sup>th</sup> July 2025

**Table:** Average water quality for Kampala Water during the period running 07<sup>th</sup> June - 13<sup>th</sup> July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Bulange Kivebulaya Rd Jn V-1564	Kisenyi Bus Terminal	Kisenyi III Kiti Zone	Wandegeya Police Station	Wankulukuku Rd/Masaka Rd Junction V-1756	Katanga Near JB Girls' Hostel	Rubaga Road SV1332	Namirembe Road/Allen Road SV	Busabala Kirinda C	Kabuuma Village Busabala
Electrical Conductivity (µs/cm)	≤1500	144	144	142	145	151	158	138	139	141	141
pH	6.5-8.5	7.6	7.6	7.2	7.6	7.4	7.6	7.2	7.2	7.2	7.3
Turbidity (NTU)	≤5	0.50	0.48	0.60	0.95	0.89	0.72	0.54	0.79	0.81	0.62
Colour – Apparent (PtCo)	≤15	4	2	5	10	9	5	2	8	6	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.45	0.20	0.20	0.40	0.30	0.20	0.40	0.40	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo

**Principal Quality Control Officer – KW**

Written by: