
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 23<sup>rd</sup> June 2025

**Table:** Average water quality for Kampala Water during the period running 16<sup>th</sup> June - 22<sup>nd</sup> June 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Katanga Soweto Zone	Nakinyuguzi Trading Center	Kansanga Market	Nsambya Hospital	Rubaga Kabusu	Sixth Street NWSC Offices	Lumumba Avenue	Buddo Trading Center	Kiswa Health Center	Bweyogerere Butto
Electrical Conductivity (µs/cm)	≤1500	131	139	130	130	136	130	137	133	139	104
pH	6.5-8.5	7.6	7.6	7.5	7.7	7.4	7.3	7.5	7.3	7.0	7.4
Turbidity (NTU)	≤5	1.36	0.73	0.57	0.60	0.63	0.53	0.90	0.44	0.46	0.67
Colour – Apparent (PtCo)	≤15	12	6	7	8	7	6	11	3	5	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.20	0.20	0.40	0.30	0.50	0.20	0.40	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**



The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo

**Principal Quality Control Officer – KW**

Written by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 23<sup>rd</sup> June 2025

**Table:** Average water quality for Kampala Water during the period running 16<sup>th</sup> June - 22<sup>nd</sup> June 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namasuba Market	Seguku Booster	Gangu Booster	Nakanako Forest Estate	Seeta 12 Miles Village	Namugongo Jjanda	Kyaliwajjala Trading Center	Green Hill Academy Buwate	Namayiba Bus Terminal	Mukono Wantoni
Electrical Conductivity (µs/cm)	≤1500	147	130	129	120	102	101	105	97	139	103
pH	6.5-8.5	7.2	7.3	7.4	7.9	7.6	7.8	7.9	7.8	7.6	7.7
Turbidity (NTU)	≤5	0.69	0.49	0.80	1.30	0.65	0.81	1.14	0.62	0.97	0.57
Colour – Apparent (PtCo)	≤15	7	3	9	12	6	8	10	6	10	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.30	0.30	0.30	0.25	0.30	0.30	0.20	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by: