
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th May 2025

Table: Average water quality for Kampala Water during the period running 19th May - 25th May 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Wakiso Mpunga Ward	Aqua Coolers Ltd - 7th Street	Kanjokya Street SV	Katanga Soweto Zone	Fire Brigade Headquarters	Lubowa Police Post	Ndeeba Kasumba Zone	Nakasero Booster	Kabojja Parents P/S	Kyengera Central College
Electrical Conductivity (µs/cm)	≤1500	143	150	149	149	147	142	142	146	141	315
pH	6.5-8.5	7.2	7.1	7.3	7.3	7.3	7.5	7.4	6.8	7.1	7.4
Turbidity (NTU)	≤5	0.51	0.67	0.66	0.66	0.16	0.86	0.16	0.49	0.47	0.55
Colour – Apparent (PtCo)	≤15	5	9	8	7	0	9	0	3	5	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.30	0.20	0.30	0.20	0.20	0.40	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th May 2025

Table: Average water quality for Kampala Water during the period running 19th May - 25th May 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Buloba PTC	Mutundwe Kisigula	Bwaise Industrial Area	Bunga market	Mpererwe Market	Komamboga Sekanyonyi zone	Manyangwa TC - Gayaza	Kisaasi Trading Center	Seeta Market	Sonde Trading Center
Electrical Conductivity (µs/cm)	≤1500	139	139	139	146	145	122	123	171	107	104
pH	6.5-8.5	7.2	7.3	7.6	7.1	7.4	7.5	7.6	7.4	7.5	7.5
Turbidity (NTU)	≤5	0.59	0.87	1.07	1.17	0.64	0.92	0.56	0.82	0.82	0.63
Colour – Apparent (PtCo)	≤15	3	10	11	11	4	6	3	6	6	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.20	0.30	0.20	0.30	0.20	0.20	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: