
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 07<sup>th</sup> July 2025

**Table:** Average water quality for Kampala Water during the period running 30<sup>th</sup> June - 06<sup>th</sup> July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nsambya Avemaria	Makindye Washing Bay	Bunga market	Arkrigh Road - Seeta	MUBS Nakawa	Ntinda Old Market	Namuwongo Market	Rubaga Cathedral	Lugala Trading Center	Ntinda Ministers' Village
Electrical Conductivity (µs/cm)	≤1500	141	143	141	97	140	120	138	138	139	179
pH	6.5-8.5	7.2	6.9	7.3	7.7	7.0	7.2	7.4	7.4	7.5	7.0
Turbidity (NTU)	≤5	0.92	1.14	0.83	0.84	1.00	0.91	1.01	0.75	1.03	1.04
Colour – Apparent (PtCo)	≤15	10	11	9	3	10	10	10	7	9	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.3	0.3	0.20	0.30	0.40	0.30	0.40	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**



The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo

**Principal Quality Control Officer – KW**

Written by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 07<sup>th</sup> July 2025

**Table:** Average water quality for Kampala Water during the period running 30<sup>th</sup> June - 06<sup>th</sup> July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kitukutwe Trading Center	Nansana Market	Katanga Mulago	St. Balikudembe Market	Bat Valley Primary School	Nakasero Market	Luzira Prisons	Kirinya Bukasa	Kabowa Village	Mukono Kayunga Road
Electrical Conductivity (µs/cm)	≤1500	106	138	137	137	137	139	136	108	142	103
pH	6.5-8.5	7.7	7.0	7.5	7.5	7.5	7.4	7.1	7.6	7.5	7.7
Turbidity (NTU)	≤5	0.29	0.51	1.59	1.25	1.09	0.86	0.71	0.72	0.74	0.55
Colour – Apparent (PtCo)	≤15	0	4	14	11	10	5	6	5	4	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.20	0.40	0.40	0.20	0.20	0.20	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by: