
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 11th August 2025

Table: Average water quality for Kampala Water during the period running 04th August - 10th August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Bwaise Happy Hours	Makerere Kubiri	Kawempe Holy Family	Najjera I	Kiwatule Trading Center	Kisaasi Trading Center	Kiteredde Village	Nsambya St. Peter's School	Makindye Kizungu Zone	Valve Near Coca Cola
Electrical Conductivity (µs/cm)	≤1500	138	138	138	109	124	109	172	157	157	92
pH	6.5-8.5	7.2	7.1	7.2	7.8	7.7	7.6	6.8	7.3	7.7	7.4
Turbidity (NTU)	≤5	0.58	0.67	0.87	0.59	0.82	0.94	0.34	0.85	1.14	0.62
Colour – Apparent (PtCo)	≤15	5	6	8	5	8	9	0	8	10	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.40	0.30	0.30	0.35	0.20	0.20	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 11th August 2025

Table: Average water quality for Kampala Water during the period running 04th August - 10th August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Arkright Road Seeta	Joggo Trading Center	Sonde Trading Center	Kitukutwe Trading Center	Bat Valley Primary School	Fairway Hotel	Bandwe Trading Center	Mbuya Comboni Sisters	Mutungo Zone 3	Nalukolongo Market
Electrical Conductivity (µs/cm)	≤1500	107	106	104	102	135	135	151	102	138	128
pH	6.5-8.5	7.8	7.9	7.9	8.0	7.5	7.6	7.2	7.7	7.2	7.6
Turbidity (NTU)	≤5	0.86	1.18	0.56	0.70	1.15	1.03	0.64	0.72	0.67	0.79
Colour – Apparent (PtCo)	≤15	7	10	6	8	12	11	5	7	6	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.25	0.30	0.40	0.30	0.30	0.35	0.20	0.40	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo

Principal Quality Control Officer – KW

Written by:



Enos Malambala

Quality Assurance Manager – KW

Approved by: