
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 21st July 2025

Table: Average water quality for Kampala Water during the period running 14th July - 20th July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nsambya Central zone	Kabalagala Market	Munyonyo SV	Kiswa Health Center	Portbell Market	Kulambiro Pal & Lisa School	Lubowa Police Post	Kanyanya Police Post	Nyanama Trading Center	Ndeebe Kasumba Zone
Electrical Conductivity (µs/cm)	≤1500	152	152	138	144	92	132	145	149	144	144
pH	6.5-8.5	7.3	7.3	7.2	6.8	6.9	6.9	7.1	7.2	7.1	7.1
Turbidity (NTU)	≤5	0.24	0.22	0.23	0.70	0.84	1.04	1.01	0.90	0.94	0.85
Colour – Apparent (PtCo)	≤15	5	5	3	8	9	10	9	10	7	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.30	0.40	0.30	0.30	0.30	0.40	0.20	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 21st July 2025

Table: Average water quality for Kampala Water during the period running 14th July - 20th July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Gayaza Trading Center	Kyanja Trading Center	Manyangwa TC - Gayaza	Bulenga Trading Center	Buloba Kiwumu Trading Center	Bulaga Police Post	Aqua Coolers Ltd - 7th Street	Fire Brigade Headquarters	Kololo York Terrace	Kyaliwajjala Trading Center
Electrical Conductivity (µs/cm)	≤1500	107	105	104	147	147	143	144	143	144	81
pH	6.5-8.5	8.0	7.8	7.8	7.3	7.1	7.4	7.2	7.2	7.2	7.6
Turbidity (NTU)	≤5	0.69	0.73	0.54	0.69	0.71	0.78	1.38	0.68	0.73	0.39
Colour – Apparent (PtCo)	≤15	6	4	0	7	7	7	13	7	7	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.50	0.30	0.20	0.20	0.20	0.30	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: