
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 28th July 2025

Table: Average water quality for Kampala Water during the period running 21st July - 27th July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Luwafu Washing Bay	Nyanama Trading Center	Buziga Islamic Institute	Kireka Market	St. Luke C.O.U Ntinda	Oryx Fuel Station Naalya	Buddo Kings College	Buloba Kiwumu TC	Bwaise Kazo zone	Butabika SV
Electrical Conductivity (µs/cm)	≤1500	145	143	145	144	121	121	144	142	146	105
pH	6.5-8.5	7.1	7.3	7.4	7.6	7.6	7.6	7.0	8.0	7.4	7.5
Turbidity (NTU)	≤5	0.76	0.46	0.65	0.67	0.89	0.87	0.82	0.65	0.98	0.80
Colour – Apparent (PtCo)	≤15	7	4	5	4	6	10	9	4	10	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.20	0.40	0.35	0.25	0.20	0.20	0.40	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 28th July 2025

Table: Average water quality for Kampala Water during the period running 21st July - 27th July 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namboole Stadium Hotel	Green Hill Academy Kibuli	Namamve Booster	Seeta Market	Mukono UCU	Kiira Trading Center	Lugogo Bypass	Buganda Royal Institute	Hotel Africana	Kawala TC Near Police
Electrical Conductivity (µs/cm)	≤1500	90	153	98	87	85	101	145	153	153	153
pH	6.5-8.5	7.5	7.5	7.4	7.7	7.4	7.8	7.4	7.1	7.4	7.5
Turbidity (NTU)	≤5	1.20	0.59	0.66	0.72	1.03	0.98	0.85	1.20	0.58	0.54
Colour – Apparent (PtCo)	≤15	10	3	4	5	9	10	9	11	6	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.50	0.40	0.30	0.40	0.30	0.40	0.40	0.40	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date: