
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 04<sup>th</sup> August 2025

**Table:** Average water quality for Kampala Water during the period running 28<sup>th</sup> July - 03<sup>rd</sup> August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Rubaga Bulwa Zone	Katwe Kinyolo	Kabalagala Market	Luzira Market	Mutungo Zone 3	Namamve Booster	Ntinda Ministers' Village	Bukoto White Flats	Kabakanjjagala Road	Kalerwe Market - Upper Wing
Electrical Conductivity (µs/cm)	≤1500	143	142	142	98	98	92	130	112	148	148
pH	6.5-8.5	7.0	7.0	6.9	7.3	7.6	7.4	7.3	7.6	7.4	7.4
Turbidity (NTU)	≤5	0.97	0.35	0.47	0.55	0.45	0.62	1.05	0.92	0.82	0.66
Colour – Apparent (PtCo)	≤15	9	2	3	3	3	6	9	11	8	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.30	0.20	0.30	0.40	0.30	0.40	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.





Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 04<sup>th</sup> August 2025

**Table:** Average water quality for Kampala Water during the period running 28<sup>th</sup> July - 03<sup>rd</sup> August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kasode Market	Namasuba St. Elizabeth	Bweyogerere Market	Kirinya SDA Church	Mbuya Comboni Sisters	Nakawa Market	Kulambiro Tuba Zone	Seeta 12 Miles Village	Mukono Market	Katosi Trading Center
Electrical Conductivity (µs/cm)	≤1500	149	144	104	101	145	143	122	103	99	93
pH	6.5-8.5	7.4	6.8	7.3	7.6	7.4	7.4	7.5	7.1	7.7	7.4
Turbidity (NTU)	≤5	0.88	0.92	0.44	0.46	1.06	0.81	0.83	0.60	0.48	0.38
Colour – Apparent (PtCo)	≤15	9	9	1	3	10	8	8	6	4	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.40	0.30	0.35	0.40	0.30	0.30	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: