
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th August 2025

Table: Average water quality for Kampala Water during the period running 11th August - 17th August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Sonde Village	Bugolobi Flats B-26	Bwaise Kusatu	Wakiso Mpuga Ward	Kasanga Market	Ntinda new market	American Embassy Nsambya	Kisenyi Kit Zone	Namilyang o Tranding Centre	Rubaga Nabunya Road
Electrical Conductivity (µs/cm)	≤1500	108	100	145	198	143	125	140	145	101	145
pH	6.5-8.5	7.8	7.6	7.5	7.0	7.3	7.6	7.0	7.2	7.7	7.3
Turbidity (NTU)	≤5	0.75	0.79	1.67	0.29	0.95	0.64	0.87	0.81	0.45	1.84
Colour – Apparent (PtCo)	≤15	6	8	15	2	10	2	8	8	0	14
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.25	0.30	0.20	0.50	0.30	0.30	0.20	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera



Julius Wanyera
Ag. Principal Quality Control Officer – KW

Written by:

Malambala

Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th August 2025

Table: Average water quality for Kampala Water during the period running 18th August - 24th August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nansana Nabweru	Wakiso Kayunga	Namuwongo Godown	Kisenyi Bus Terminus	Matuga Kyogwa Zone	AM Luzira Water Village	Kisoga Trading Centre	Bugolobi Sewerage Works	Kigo Lunya	Wankulunkuku Market
Electrical Conductivity (µs/cm)	≤1500	144	203	143	143	144	141	94	145	141	140
pH	6.5-8.5	7.2	7.4	7.4	7.0	7.5	7.5	7.4	7.4	6.8	7.4
Turbidity (NTU)	≤5	0.85	0.43	1.06	0.78	1.03	1.31	0.36	1.45	1.51	1.76
Colour – Apparent (PtCo)	≤15	7	0	9	7	14	11	2	13	15	15
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.2	0.40	0.20	0.20	0.40	0.40	0.50	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera

Julius Wanyera

Ag. Principal Quality Control Officer – KW

Written by:

Malambala

Enos Malambala

Quality Assurance Manager – KW

Approved by: